

Scatchett Head WD

Monthly Operations -

August

2023

Water pumped:

	Cu. Ft. Start	Cu. Ft. End	Cu. Ft. Month	Gals. Month
Well # 2	9,859,020	10,103,330	244,310	1,827,439
Well # 3	7,869,090	8,013,160	144,070	1,077,644
Total			388,380	2,905,082

Treatment Meter:

	63,563,200	64,518,100	954,900	7,142,652
--	------------	------------	---------	-----------

Difference

			-566,520	-4,237,570
--	--	--	----------	------------

Backwash

	5,854,100	5,936,400	82,300	
--	-----------	-----------	--------	--

Backwash %

21.2%

Cottage Glen reservoir

				Gallons
Inlet meter (Cu. Ft.)	581,840	635,207	53,367	399,185
Outlet meter (Cu. Ft.)	8,105,590	8,140,830	35,240	263,595

Difference

135,590

Booster Pumps:

#1	10,822	10,941	119	
#2	11,029	11,188	159	
#3	12,652	12,805	153	
#4	10,578	10,629	51	
			482	

Booster gals/hr.

Flushing	Cu Ft	Gallons
2021		
March - full system flush		100,000
June - full system flush		100,645
Sept - full system flush		100,000
Dec - full system flush		100,000
2022		
March - full system flush		100,000
June - full system flush		100,000
Sept - full system flush		63,000
Dec - full system flush		100,000
2023		
March - full system flush		100,000
June - full system flush		100,000