

## Scatchett Head WD

Monthly Operations - September 2023

Water pumped:

	Cu. Ft. Start	Cu. Ft. End	Cu. Ft. Month	Gals. Month
Well # 2	9,859,020	10,103,330	244,310	1,827,439
Well # 3	7,869,090	8,013,160	144,070	1,077,644
<b>Total</b>			388,380	2,905,082

Treatment Meter:

	63,563,200	64,518,100	954,900	7,142,652
--	------------	------------	---------	-----------

Difference

-566,520    -4,237,570 \*

Backwash

5,854,100	5,936,400	82,300
-----------	-----------	--------

Backwash %

21.2%

Cottage Glen reservoir

	Cu. Ft.	Cu. Ft.	Cu. Ft.	Gallons
Inlet meter (Cu. Ft.)	581,840	635,207	53,367	399,185
Outlet meter (Cu. Ft.)	8,105,590	8,140,830	35,240	263,595

Difference

135,590

Booster Pumps:

#1	10,822	10,941	119
#2	11,029	11,188	159
#3	12,652	12,805	153
#4	10,578	10,629	51
			482

Booster gals/hr.

<u>Flushing</u>	Cu Ft	Gallons
<b>2021</b>		
March - full system flush		100,000
June - full system flush		100,645
Sept - full system flush		100,000
Dec - full system flush		100,000
<b>2022</b>		
March - full system flush		100,000
June - full system flush		100,000
Sept - full system flush		63,000
Dec - full system flush		100,000
<b>2023</b>		
March - full system flush		100,000
June - full system flush		100,000
Sept - full system flush		100,000