

Scatchett Head WD

Monthly Operations -

October

2023

Water pumped:

	Cu. Ft. Start	Cu. Ft. End	Cu. Ft. Month	Gals. Month
Well # 2	10,366,640	10,619,710	253,070	1,892,964
Well # 3	8,057,290	8,084,460	27,170	203,232
Total			280,240	2,096,195

Treatment Meter:

	65,055,000	65,376,900	321,900	2,407,812
--	------------	------------	---------	-----------

Difference

	-41,660	-311,617
--	---------	----------

Backwash

	6,004,500	6,082,700	78,200
--	-----------	-----------	--------

Backwash %

27.9%

Cottage Glen reservoir

Gallons

Inlet meter (Cu. Ft.)	8,209,000	8,261,770	52,770	394,720
Outlet meter (Cu. Ft.)	702,583	755,844	53,261	398,392

Difference

(3,673)

Booster Pumps:

#1	11,051	11,096	45
#2	11,467	11,582	115
#3	12,936	12,999	63
#4	10,694	10,741	47

270

Booster gals/hr.

Flushing

Cu Ft Gallons

2021

March - full system flush	100,000
June - full system flush	100,645
Sept - full system flush	100,000
Dec - full system flush	100,000

2022

March - full system flush	100,000
June - full system flush	100,000
Sept - full system flush	63,000
Dec - full system flush	100,000

2023

March - full system flush	100,000
June - full system flush	100,000
Sept - full system flush	100,000